






50 AMP GFCI 6-3 Wire standard for all spas in the USA



This ground connection must be the two whitewires tied together only. Don't tie them to the regular ground block. These are the curly white wire from the Breaker and the white wire from the breaker box. The white wire to the spa



connects to the bottom of the GFCI breaker.



You should have a disconnect at the spa for all applications